



Filing Receipt

Received - 2022-01-12 09:50:16 AM
Control Number - 52667
ItemNumber - 27



Rio Grande Electric Cooperative, Inc.

Project No. 52667 Compliance Report

This report was prepared by Rio Grande Electric Cooperative, Inc. (RGE) to comply with PUCT Project No. 52667 regarding the Filing of Attestations Demonstrating Compliance with HB 4150.

Report Date	January 4, 2022
Entity	Rio Grande Electric Cooperative, Inc.
ERCOT Entity Type	Distribution Service Provider
Lake listed in PURA § 38.004(b) in Rio Grande EC Service Area	Lake Amistad Reservoir
County of Lake and Distribution Line(s)	Val Verde



Line and Compliance Information			
Line Identifier	Compliance with NESC 232	Compliance Confirmation Date	Notes
Rough Canyon Marina – Line Segment POH20301064374	Yes	11/3/2021	Existing overhead electric power line structures and conductor spans were field surveyed and verified to be in compliance with NESC 232.
Sanderson Point – Line Segment POH20301042931	Yes	12/13/2021	Existing overhead electric power line structures and conductor spans were field surveyed and verified to be in compliance with NESC 232.

PROJECT NO. 52667

FILING OF ATTESTATION DEMONSTRATING COMPLIANCE WITH HB 4150

AFFIDAVIT OF COOPERATIVE OFFICER FOR

RIO GRANDE ELECTRIC COOPERATIVE, INC.

FILED PURSUANT TO SECTION 6 HOUSE BILL 4150

STATE OF TEXAS §

COUNTY OF KINNEY §

BEFORE ME, the undersigned authority, on this day personally appeared, and who, after being duly sworn, stated on his or her oath he or she is entitled to make this Affidavit, and that the statements contained below are true and correct.

I, Rogelio Andrade, swear or affirm that as an Electric Cooperative operating in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system, confirms the following:

- Rio Grande Electric Cooperative, Inc. (RGEC) operates a transmission and distribution utility system in the State of Texas and the Electric Reliability Council of Texas (ERCOT) region and control system;
- RGEC owns two (2) distribution lines over lakes listed in PURA § 38.004(b).
- The report prepared by RGEC, titled **Project No. 52667 Compliance Report**, certifies that these distribution lines meet the applicable vertical clearance requirements established in Rule 232 of the NESC Standard ANSI (c)(2).




{Signature of Officer of the Cooperative}

Rogelio Andrade

Chief Executive Officer

Rio Grande Electric Cooperative, Inc.

Sworn and subscribed before me on this 12th day of January, 2022.



Notary Public in and for the State of Texas

Notary

